

## [Chapter 15.04 SUBDIVISIONS](#)

---

### **Section 15.04.760 Joints.**

Joints shall be provided for sidewalk and curb and gutter as follows:

A. Sidewalks: shall have scribed joints at intervals of four feet which joints shall be approximately three-sixteenth inches wide and be approximately one-third of the total slab thickness. In addition, one-half inch expansion joints shall be provided at thirty-two (32) foot intervals and at locations where sidewalks adjoin curbs or existing sidewalks. Slabs shall be ruled at four-foot intervals.

B. Curb and gutter: shall be cut into lengths of ten (10) feet by the use of one-eighth inch steel division plates of the exact cross section of the curb and gutter or shall be scribed when installed by a laydown machine. Also, one-half inch expansion joints shall be provided at curb and gutter radii, where the curb and gutter abuts a solid object and at intervals not to exceed fifty (50) feet.

Material for one-half inch expansion joints shall be as defined in AASHTO M-33, and shall be installed with its top approximately one-quarter inch below the concrete surface. (Ord. 5-1988 § 1 (part); Development Code § 4-6-5)